

COUNTY OF LOS ANGELES FIRE DEPARTMENT

FIRE PREVENTION DIVISION

FUELED VEHICLES IN ASSEMBLY BUILDINGS PERMIT REQUIREMENTS

Article 1, Section 105 of the Los Angeles County Fire Code states... a permit shall be obtained from the Fire Prevention Division prior to engaging in the following:... to display, compete or demonstrate liquid- or gasfueled vehicles or equipment in assembly buildings. See article 25. Additional requirements may be applicable.

<u>GENERAL</u> Liquid- and gas-fueled vehicles and equipment used for display, competition or demonstration within assembly occupancies shall be in accordance with Section 2505.

DISPLAYS

<u>GENERAL</u> Display of liquid- and gas-fueled vehicles and equipment inside an assembly occupancy shall be in accordance with Section 2505.2

BATTERIES Batteries shall be disconnected in an approved manner.

FUEL SYSTEMS

FUELING Vehicles or equipment shall not be fueled or defueled within the building.

QUANTITY LIMIT Fuel in the fuel tank shall not exceed one quarter of the tank capacity or 5 gallons (18.9L), whichever is less.

INSPECTION Fuel systems shall be inspected for leaks.

CLOSURE Fuel-tank openings shall be locked and sealed to prevent the escape of vapors.

LOCATION The location of vehicles or equipment shall not obstruct or block means of egress.